

A BUILDING SECTION
SCALE= 1/8" : 1'-0"

PIPE LEGEND
- BLACK STEEL FIRE SPRINKLER PIPING
- CPVC FIRE SPRINKLER PIPING
- FIRE SPRINKLER STANDPIPE PIPING

SYM	CNT	POSITION	FINISH	TEMP	K	NPT	SIN	MFG.	MODEL#	ESCUTCHEON	MAX SPACING
	1	SIDEWALL	BRASS	200	11.20	3/4"	TY5332	TYCO	ELOSW20	SEMI-RECESS	16'x20'
	90	UPRIGHT	BRASS	200	5.60	1/2"	V2703	VICTAULIC	FL-SR	N/A	130 SF
	37	UPRIGHT	BRASS	200	14.00	3/4"	V3425	VICTAULIC	FL-ECOH	N/A	20'x20'
	94	PENDENT	WHITE	200	5.60	1/2"	V2708	VICTAULIC	FL-QR	SEMI-RECESS	15'x15', 130 SF OH
	268	UPRIGHT	BRASS	200	5.60	1/2"	V2704	VICTAULIC	FL-QR	N/A	15'x15', 130 SF OH
	376	PENDENT	WHITE	155	4.90	1/2"	V4906	VICTAULIC	FL-RES	SEMI-RECESS	18'x18' UNO
	69	SIDEWALL	WHITE	200	5.60	1/2"	V2710	VICTAULIC	FL-QR	SEMI-RECESS	14'x14', 130 SF OH
	171	SIDEWALL	WHITE	155	4.40	1/2"	V4431	VICTAULIC	FL-RES/SW	SEMI-RECESS	16'x16'
	11	SIDEWALL	WHITE	155	4.00	1/2"	V5485	VIKING	FREEDOM	SEMI-RECESS	16'x16'
	13	PENDENT	WHITE	200	2.80	1/2"	V4215	VICTAULIC	FL-QR	SEMI-RECESS	15'x15'
	9	SPRIG	BRASS	200	5.60	1/2"	V2704	VICTAULIC	FL-QR	N/A	15'x15'
	48	UPRIGHT	BRASS	200	4.20	1/2"	V4215	VICTAULIC	FL-QR	N/A	130 SF
	2	SIDEWALL	WHITE	200	4.20	1/2"	V4226	VICTAULIC	FL-QR	SEMI-RECESS	14'x14'
1189 TOTAL SPRINKLERS											

SPRINKLER HEAD LEGEND

NFPA 13 STEEL PIPE HANGER SPACING (EXCEPT LIGHT WALL THRD PIPING)	
NOMINAL SIZE inches	MAX SPACING feet
1"	12'-0"
1-1/4"	12'-0"
1-1/2"	15'-0"
2"	15'-0"
2-1/2"	15'-0"
3"	15'-0"
4" & LARGER	15'-0"

NFPA 13 CPVC PIPE HANGER SPACING	
NOMINAL SIZE inches	MAX SPACING feet
3/4"	5'-6"
1"	6'-0"
1-1/4"	6'-6"
1-1/2"	7'-0"
2"	8'-0"
2-1/2"	9'-0"
3"	10'-0"



HANGER DETAILS

GENERAL NOTES

1. MINNESOTA STATE BUILDING CODE (2020)

   1.1. OCCUPANCY: R-2, S-2, B, A-3
   1.2. TYPE OF CONSTRUCTION: IA FOR S-2; VB FOR R-2
   1.3. SPRINKLERED AREAS (APPROXIMATE - SEE ARCHITECTURAL PLANS FOR ACTUAL)
   GARAGE (ZONE 1) = 25,272 S.F.
   1ST FLOOR (ZONE 2) = 25,877 S.F.
   2ND FLOOR (ZONE 3) = 24,208 S.F.
   3RD FLOOR (ZONE 3) = 21,480 S.F.
   ATTIC (ZONE 4) = 25,877 S.F.
   TOTAL = 122,714 S.F.

   1.4. INSTALLATION STANDARDS:
   SPRINKLER SYSTEM DESIGNED AND INSTALLED PER **NFPA-13 (2016)**

2. SPRINKLER PIPE TYPES:
   -WET-
   2.1. 1" BRANCH LINES TO BE BLAZEMASTER CPVC PIPING WITH CEMENTED FITTINGS
   2.2. 1-1/4" THROUGH 2" MAIN & BRANCH LINES TO BE BLAZEMASTER CPVC PIPING WITH CEMENTED FITTINGS
   2.3. 1" BRANCH LINES TO BE MEGA THREAD PIPING WITH THREADED FITTINGS
   2.4. 1-1/4" THROUGH 4" MAIN & BRANCH LINES TO BE MEGA FLOW PIPING WITH SHORT RADIUS GROOVED FITTINGS
   -DRY-
   2.5. 1" BRANCH LINES TO BE THREADED SCHEDULE 40 WITH THREADED FITTINGS
   2.6. 1-1/4" THROUGH 6" MAIN & BRANCH LINES TO BE GROOVED SCHEDULE 10 WITH SHORT RADIUS GROOVED FITTINGS
   2.7. 1" SPRIGS TO BE SCHEDULE 40 WITH THREADED FITTINGS

3. DESIGN CRITERIA
   3.1. PARKING LEVEL, RISER ROOM & SIMILAR AREAS ARE DESIGNED TO ORDINARY HAZARD GROUP 1
   3.1. RESIDENTIAL UNITS, ATTIC & SIMILAR AREAS ARE DESIGNED TO LIGHT HAZARD
   3.2. REMOTE AREA REDUCTIONS HAVE BEEN TAKEN WHERE APPLICABLE PER NFPA 13 SEC. 11.2.3.2.3

4. NOTES:
   4.1. ALL MATERIAL TO BE NEW AND MEET U.L. STANDARDS
   4.2. HANGERS TO BE INSTALLED IN ACCORDANCE WITH NFPA 13 (2016) - **SEE PLAN FOR HANGING REQ.**
   4.3. DRY SYSTEM PIPE SLOPE INSTALLATION:
   SPRINKLER MAINS TO BE ½" PER 10 FEET
   SPRINKLER BRANCH LINES TO BE ½" PER 10 FEET
   4.4. DRY SYSTEM CAPACITY
   1358.9 GAL.

5. SYMBOLS USED ON DRAWINGS:
   - +10" PIPE ELEVATION A.F.F
   - -48" PIPE ELEVATION BELOW B.O.D
   - OH1 ROOM HAZARD CLASSIFICATION (ALL ROOMS ARE CONSIDERED LIGHT HAZARD UNLESS NOTED)
   - F1 HYDRAULIC CALCULATION JUNCTION POINT
   - 0'-0" CEILING HEIGHT

6. SCOPE OF WORK:
   6.1. TO INSTALL A NEW SPRINKLER SYSTEM IN THE VIEWS ON 7TH. THE SYSTEM SHALL HAVE 4 ZONES; ZONE 1 FEEDING THE PARKING GARAGE. ZONE 2, FEEDING 1ST FLOOR UNITS. ZONE 3, FEEDING 2ND & 3RD FLOORS (COMBINED). ZONE 4 FEEDING THE DRY ATTIC. 1-1/2" CLEANUP STANDPIPES INSTALLED IN BOTH STAIR WELLS.
   6.2. ALL AREAS OF THE BUILDING TO BE INSTALLED AND COVERED IN ACCORDANCE WITH THE LOCAL AUTHORITY HAVING JURISDICTION AND PER NFPA 13 (2016).



B BUILDING SECTION
SCALE= 1/8" : 1'-0"



RISER LEGEND
1. 6" UNDERGROUND WATER SERVICE (BY OTHERS)
   (FLUSHING & TESTING OF THE UNDERGROUND SHALL BE COMPLETED PRIOR TO THE SPRINKLER SYSTEM HOOKUP. UNDERGROUND PAPERS ARE TO BE SUPPLIED TO THE "FP" CONTRACTOR BY THE G.C.)
2. 6"x4" GROOVED REDUCER
3. 4" APOLLO DCLF 4A BACKFLOW GXG w/ TAMPER SWITCHES
4. 4" GROOVED BUTTERFLY VALVE w/ TAMPER SWITCH
5. 4" VICTAULIC FIRELOCK NXT DRY VALVE w/ QUICK OPENING DEVIC
6. 6" OUT TO ATTIC (ZONE 4)
7. 4" OUT TO FDC
8. 2-1/2" VICTAULIC SERIES UM UNIVERSIAL MANIFOLD ASSEMBLY
9. 2-1/2" OUT TO PARKING GARAGE (ZONE 1)
10. 2-1/2" OUT TO 1ST FLOOR (ZONE 2)
11. 2-1/2" OUT TO 2ND FLOOR (ZONE 3)
12. 1-1/2" OUT TO STANDPIPES
13. AIR COMPRESSOR
14. MAIN DRAIN PIPE TO EXTERIOR
15. SPARE HEAD BOX
16. PIPE STAND

* ALL WIRING/INTERFACING OF ALARMS BY OTHERS

* ALL PIPING PENETRATING THE EXTERIOR WALL TO BE GALVANIZED

1 RISER DETAIL
SCALE= 1/2" : 1'-0"



SITE PLAN
SCALE: 1" = 50'-0"



GENERAL NOTES

1. SYSTEM INSTALLED PER NFPA-13 (2016 EDITION) AND STATE FIRE MARSHAL
2. ALL EQUIPEMENT FOR THIS SYSTEM SHALL BE U.L. LISTED
3. MINIMUM PIPE SIZE SHALL BE 1" NOMINAL PIPE
4. ALL SCH-10 & LIGHTWALL PIPING HAS WELDED OUTLETS & GROOVED SHORT RADIUS FITTINGS ALL WELDING PER NFPA-13(3.6.2)
5. NO INSTALLATION OR FABRICATION TO BEGIN WITHOUT APPROVED SHOP DRAWINGS
6. ALL PIPE LOCATIONS ARE TO BE FIELD MEASURED PRIOR TO FABRICATON AND INSTALLTION BY SPRINKLER CONTRACTOR
7. ALL DIMENSIONS SHOWN ARE CENTER TO CENTER
8. HIGH TEMPERATURE HEADS ARE TO BE FIELD LOCATED WHERE REQUIRED
9. PROVIDE ON SPARE HEAD CABINET w/6 HEADS & 1 HEAD WRENCH
10. HANGERS ARE TO BE U.L. LISTED AND F.M. APPROVED
11. ELECTRICAL WIRING, ALARM, DETECTION AND SUPERVISORY BY OWNER
12. OWNER'S RESPONSIBILITY TO PROVIDE ADEQUATE HEATING TO PREVENT WET SYSTEM PIPING FROM FREEZING.

NO	REVISIONS	DATE
1	AHJ REVISIONS	10/15/2025

APPROVAL STAMPS

Drawing Title: FIRE PROTECTION PLAN

THE VIEWS ON 7TH
7TH AVENUE SE
LITTLE FALLS, MN 56345

Contract No. C25-9

Drawing Date:	6/9/25
Scale:	1/8" = 1'-0"
Drawn By:	DVG
Approval By:	STATE FIRE MARSHAL DIV.
SHEET NO.	FP 1 of 6

Design Area #: **12**	HAZARD: **OHII**
Zone: **1**	System Type: **WET**
Location: **STORAGE 03**	
Flowing Outlets: **21**	
Density: **0.20**	Remote Area: **925**
Flow: **487.9** gpm	@ **29.7** psi
Calculation Safety: **31.0** psi	
Includes **250** gpm Hose allowance	

NOTE:
CALCULATED PER ROOM DESIGN METHOD
NFPA 13 SEC. 11.2.3.3.



GARAGE FLOOR-A FIRE SPRINKLER PLAN

SCALE= 1/8" : 1'-0"



KEY PLAN



CALC PLACARD

Design Area #: **7**	HAZARD: **OHI**
Zone: **1**	System Type: **WET**
Location: **PARKING GARAGE**	
Flowing Outlets: **8**	
Density: **0.15**	Remote Area: **1554**
Flow: **493.0** gpm	@ **38.6** psi
Calculation Safety: **22.1** psi	
Includes **250** gpm Hose allowance	

NOTE:
1500 S.F. REMOTE AREA USED DUE TO THE USE OF STANDARD RESPONSE SPRINKLERS. GRID IS PEAKED.

GARAGE FLOOR-B FIRE SPRINKLER PLAN

SCALE= 1/8" : 1'-0"



KEY PLAN

PIPE LEGEND

- BLACK STEEL FIRE SPRINKLER PIPING
- CPVC FIRE SPRINKLER PIPING
- FIRE SPRINKLER STANDPIPE PIPING

SYM	CNT	POSITION	FINISH	TEMP	K	NPT	S/N	MFG.	MODEL#	ESCUTCHEON	MAX SPACING
	1	SIDEWALL	BRASS	200	11.20	3/4"	TY5332	TYCO	ELOSW20	SEMI-RECESS	16'x20'
	90	UPRIGHT	BRASS	200	5.60	1/2"	V2703	VICTAULIC	FL-SR	N/A	130 SF
	37	UPRIGHT	BRASS	200	14.00	3/4"	V3425	VICTAULIC	FL-ECOH	N/A	20'x20'
	94	PENDENT	WHITE	200	5.60	1/2"	V2708	VICTAULIC	FL-QR	SEMI-RECESS	15'x15'; 130 SF OH
	268	UPRIGHT	BRASS	200	5.60	1/2"	V2704	VICTAULIC	FL-QR	N/A	15'x15'; 130 SF OH
	376	PENDENT	WHITE	155	4.90	1/2"	V4906	VICTAULIC	FL-RES	SEMI-RECESS	18'x18' UNO
	69	SIDEWALL	WHITE	200	5.60	1/2"	V2710	VICTAULIC	FL-QR	SEMI-RECESS	14'x14'; 130 SF OH
	171	SIDEWALL	WHITE	155	4.40	1/2"	V4431	VICTAULIC	FL-RES/SW	SEMI-RECESS	16'x16'
	11	SIDEWALL	WHITE	155	4.00	1/2"	V6486	VIKING	FREEDOM	SEMI-RECESS	16'x16'
	13	PENDENT	WHITE	200	2.80	1/2"	V4215	VICTAULIC	FL-QR	SEMI-RECESS	15'x15'
	9	SPRIG	BRASS	200	5.60	1/2"	V2704	VICTAULIC	FL-QR	N/A	15'x15'
	48	UPRIGHT	BRASS	200	4.20	1/2"	V4215	VICTAULIC	FL-QR	N/A	130 SF
	2	SIDEWALL	WHITE	200	4.20	1/2"	V4226	VICTAULIC	FL-QR	SEMI-RECESS	14'x14'
	1189 TOTAL SPRINKLERS										

SPRINKLER HEAD LEGEND

N W E S

GENERAL NOTES

1. SYSTEM INSTALLED PER NFPA-13 (2016 EDITION) AND STATE FIRE MARSHAL
2. ALL EQUIPEMENT FOR THIS SYSTEM SHALL BE U.L. LISTED
3. MINIMUM PIPE SIZE SHALL BE 1" NOMINAL PIPE
4. ALL SCH-10 & LIGHTWALL PIPING HAS WELDED OUTLETS & GROOVED SHORT RADIUS FITTINGS ALL WELDING PER NFPA-13(3-6.2)
5. NO INSTALLATION OR FABRICATION TO BEGIN WITHOUT APPROVED SHOP DRAWINGS
6. ALL PIPE LOCATIONS ARE TO BE FIELD MEASURED PRIOR TO FABRICATON AND INSTALLTION BY SPRINKLER CONTRACTOR
7. ALL DIMENSIONS SHOWN ARE CENTER TO CENTER
8. HIGH TEMPERATURE HEADS ARE TO BE FIELD LOCATED WHERE REQUIRED
9. PROVIDE ON SPARE HEAD CABINET w/6 HEADS & 1 HEAD WRENCH
10. HANGERS ARE TO BE U.L. LISTED AND F.M. APPROVED
11. ELECTRICAL WIRING, ALARM, DETECTION AND SUPERVISORY BY OWNER
12. OWNER'S RESPONSIBILITY TO PROVIDE ADEQUATE HEATING TO PREVENT WET SYSTEM PIPING FROM FREEZING.

NO	REVISIONS	DATE
1	AHJ REVISIONS	10/15/2025

APPROVAL STAMPS

Drawing Title: FIRE PROTECTION PLAN

THE VIEWS ON 7TH

7TH AVENUE SE
LITTLE FALLS, MN 56345

Contract No. C25-9

Drawing Date: 6/9/25

Scale: 1/8" = 1'-0"

Drawn By: DVG

Approval By: STATE FIRE MARSHAL DIV.

SHEET NO. FP 2 of 6



SECOND FLOOR-A FIRE SPRINKLER PLAN

SCALE= 1/8" : 1'-0"

PIPE LEGEND

- BLACK STEEL FIRE SPRINKLER PIPING
- CPVC FIRE SPRINKLER PIPING
- FIRE SPRINKLER STANDPIPE PIPING

SYM	CNT	POSITION	FINISH	TEMP	K	NPT	SIN	MFG.	MODEL#	ESCUTCHEON	MAX SPACING
	1	SIDEWALL	BRASS	200	11.20	3/4"	TY5332	TYCO	ELOSW20	SEMI-RECESS	16'x20'
	90	UPRIGHT	BRASS	200	5.60	1/2"	V2703	VICTAULIC	FL-SR	N/A	130 SF
	37	UPRIGHT	BRASS	200	14.00	3/4"	V3425	VICTAULIC	FL-ECOH	N/A	20'x20'
	94	PENDENT	WHITE	200	5.60	1/2"	V2708	VICTAULIC	FL-QR	SEMI-RECESS	15'x15'; 130 SF OH
	268	UPRIGHT	BRASS	200	5.60	1/2"	V2704	VICTAULIC	FL-QR	N/A	15'x15'; 130 SF OH
	376	PENDENT	WHITE	155	4.90	1/2"	V4906	VICTAULIC	FL-RES	SEMI-RECESS	18'x18' UNO
	69	SIDEWALL	WHITE	200	5.60	1/2"	V2710	VICTAULIC	FL-QR	SEMI-RECESS	14'x14'; 130 SF OH
	171	SIDEWALL	WHITE	155	4.40	1/2"	V4431	VICTAULIC	FL-RES/SW	SEMI-RECESS	16'x16'
	11	SIDEWALL	WHITE	155	4.00	1/2"	V6486	VIKING	FREEDOM	SEMI-RECESS	16'x16'
	13	PENDENT	WHITE	200	2.80	1/2"	V4215	VICTAULIC	FL-QR	SEMI-RECESS	15'x15'
	9	SPRIG	BRASS	200	5.60	1/2"	V2704	VICTAULIC	FL-QR	N/A	15'x15'
	48	UPRIGHT	BRASS	200	4.20	1/2"	V4215	VICTAULIC	FL-QR	N/A	130 SF
	2	SIDEWALL	WHITE	200	4.20	1/2"	V4226	VICTAULIC	FL-QR	SEMI-RECESS	14'x14'
	1189 TOTAL SPRINKLERS										

SPRINKLER HEAD LEGEND



KEY PLAN



SECOND FLOOR-B FIRE SPRINKLER PLAN

SCALE= 1/8" : 1'-0"



KEY PLAN



Design Area #: **11** HAZARD: **LIGHT**
Zone: **4** System Type: **DRY**
Location: **COMMUNITY ATTIC**

Flowing Outlets: **30**
Density: **0.10** Remote Area: **2581**
Flow: **597.8** gpm @ **53.5** psi
Calculation Safety: **6.6** psi
Includes **100** gpm Hose allowance

NOTE:
REMOTE AREA INCREASED 30% FOR DRY SYSTEM AND 30% FOR SLOPE OF 4:12. MINIMUM TOTAL REMOTE AREA IS 2535 S.F.

CALC PLACARD

Design Area #: **4** HAZARD: **LIGHT**
Zone: **3** System Type: **WET**
Location: **UNIT TYPE 2B 211**

Flowing Outlets: **4**
Density: **0.10** Remote Area: **659**
Flow: **180.6** gpm @ **48.5** psi
Calculation Safety: **13.3** psi
Includes **100** gpm Hose allowance

NOTE:
FOUR MOST DEMANDING ADJACENT RESIDENTIAL SPRINKLERS CALCULATED PER NFPA 13 SEC. 11.3.1

Design Area #: **5** HAZARD: **LIGHT**
Zone: **3** System Type: **WET**
Location: **FLEX SPACE 234**

Flowing Outlets: **4**
Density: **0.10** Remote Area: **493**
Flow: **191.1** gpm @ **48.1** psi
Calculation Safety: **13.6** psi
Includes **100** gpm Hose allowance

NOTE:
CALCULATED PER ROOM DESIGN METHOD NFPA 13 SEC. 11.2.3.3.

Design Area #: **8** HAZARD: **LIGHT**
Zone: **3** System Type: **WET**
Location: **CORRIDOR 231**

Flowing Outlets: **4**
Density: **0.10** Remote Area: **419**
Flow: **169.2** gpm @ **44** psi
Calculation Safety: **17.8** psi
Includes **100** gpm Hose allowance

NOTE:
FOUR MOST DEMANDING ADJACENT RESIDENTIAL SPRINKLERS CALCULATED PER NFPA 13 SEC. 11.3.1



GENERAL NOTES

1. SYSTEM INSTALLED PER NFPA-13 (2016 EDITION) AND STATE FIRE MARSHAL
2. ALL EQUIPEMENT FOR THIS SYSTEM SHALL BE U.L. LISTED
3. MINIMUM PIPE SIZE SHALL BE 1" NOMINAL PIPE
4. ALL SCH-10 & LIGHTWALL PIPING HAS WELDED OUTLETS & GROOVED SHORT RADIUS FITTINGS ALL WELDING PER NFPA-13(3-6.2)
5. NO INSTALLATION OR FABRICATION TO BEGIN WITHOUT APPROVED SHOP DRAWINGS
6. ALL PIPE LOCATIONS ARE TO BE FIELD MEASURED PRIOR TO FABRICATION AND INSTALLTION BY SPRINKLER CONTRACTOR
7. ALL DIMENSIONS SHOWN ARE CENTER TO CENTER
8. HIGH TEMPERATURE HEADS ARE TO BE FIELD LOCATED WHERE REQUIRED
9. PROVIDE ON SPARE HEAD CABINET w/6 HEADS & 1 HEAD WRENCH
10. HANGERS ARE TO BE U.L. LISTED AND F.M. APPROVED
11. ELECTRICAL WIRING, ALARM, DETECTION AND SUPERVISORY BY OWNER
12. OWNER'S RESPONSIBILITY TO PROVIDE ADEQUATE HEATING TO PREVENT WET SYSTEM PIPING FROM FREEZING.

NO	REVISIONS	DATE
1	AHJ REVISIONS	10/15/2025

APPROVAL STAMPS

Drawing Title: FIRE PROTECTION PLAN

THE VIEWS ON 7TH

7TH AVENUE SE
LITTLE FALLS, MN 56345

Contract No. C25-9

Drawing Date:	6/9/25
Scale:	1/8" = 1'-0"
Drawn By:	DVG
Approval By:	STATE FIRE MARSHAL DIV.
SHEET NO.	FP 4 of 6

Design Area # **10** HAZARD: **LIGHT**
Zone: **4** System Type: **DRY**
Location: **LOWER ATTIC**

Flowing Outlets: **26**
Density: **0.10** Remote Area: **2536**
Flow: **568** gpm @ **51** psi
Calculation Safety: **9.3** psi
Includes **100** gpm Hose allowance

NOTE:
REMOTE AREA INCREASED 30% FOR DRY SYSTEM AND 30% FOR SLOPE OF 4:12.
MINIMUM TOTAL REMOTE AREA IS 2535 S.F.



THIRD FLOOR-A FIRE SPRINKLER PLAN

SCALE= 1/8" : 1'-0"



KEY PLAN



THIRD FLOOR-B FIRE SPRINKLER PLAN

SCALE= 1/8" : 1'-0"

Design Area # **1** HAZARD: **LIGHT**
Zone: **3** System Type: **WET**
Location: **CORRIDOR 331**

Flowing Outlets: **4**
Density: **0.10** Remote Area: **374**
Flow: **152.9** gpm @ **41** psi
Calculation Safety: **20.9** psi
Includes **100** gpm Hose allowance

NOTE:
FOUR MOST DEMANDING ADJACENT RESIDENTIAL SPRINKLERS CALCULATED PER NFPA 13 SEC. 11.3.1

Design Area # **2** HAZARD: **LIGHT**
Zone: **3** System Type: **WET**
Location: **UNIT TYPE 1B 303**

Flowing Outlets: **4**
Density: **0.10** Remote Area: **673**
Flow: **173.4** gpm @ **53.7** psi
Calculation Safety: **8.1** psi
Includes **100** gpm Hose allowance

NOTE:
FOUR MOST DEMANDING ADJACENT RESIDENTIAL SPRINKLERS CALCULATED PER NFPA 13 SEC. 11.3.1

Design Area # **3** HAZARD: **LIGHT**
Zone: **3** System Type: **WET**
Location: **FLEX SPACE 334**

Flowing Outlets: **5**
Density: **0.10** Remote Area: **493**
Flow: **185.0** gpm @ **43.1** psi
Calculation Safety: **18.7** psi
Includes **100** gpm Hose allowance

NOTE:
CALCULATED PER ROOM DESIGN METHOD NFPA 13 SEC. 11.2.3.3.

CALC PLACARD



KEY PLAN

PIPE LEGEND

- BLACK STEEL FIRE SPRINKLER PIPING
- CPVC FIRE SPRINKLER PIPING
- FIRE SPRINKLER STANDPIPE PIPING

SYM	CNT	POSITION	FINISH	TEMP	K	NPT	SIN	MFG.	MODEL#	ESCUTCHEON	MAX SPACING
	1	SIDEWALL	BRASS	200	11.20	3/4"	TY5332	TYCO	ELOSW20	SEMI-RECESS	16'x20'
	90	UPRIGHT	BRASS	200	5.60	1/2"	V2703	VICTAULIC	FL-SR	N/A	130 SF
	37	UPRIGHT	BRASS	200	14.00	3/4"	V3425	VICTAULIC	FL-ECOH	N/A	20'x20'
	84	PENDENT	WHITE	200	5.60	1/2"	V2708	VICTAULIC	FL-QR	SEMI-RECESS	15'x15'; 130 SF OH
	268	UPRIGHT	BRASS	200	5.60	1/2"	V2704	VICTAULIC	FL-QR	N/A	15'x15'; 130 SF OH
	376	PENDENT	WHITE	155	4.90	1/2"	V4906	VICTAULIC	FL-RES	SEMI-RECESS	18'x18' UNO
	69	SIDEWALL	WHITE	200	5.60	1/2"	V2710	VICTAULIC	FL-QR	SEMI-RECESS	14'x14'; 130 SF OH
	171	SIDEWALL	WHITE	155	4.40	1/2"	V4431	VICTAULIC	FL-RES/SW	SEMI-RECESS	16'x16'
	11	SIDEWALL	WHITE	155	4.90	1/2"	V5486	VIKING	FRESIDSW	SEMI-RECESS	16'x16'
	13	PENDENT	WHITE	200	2.80	1/2"	V4215	VICTAULIC	FL-QR	SEMI-RECESS	15'x10'
	9	SPRIG	BRASS	200	5.60	1/2"	V2704	VICTAULIC	FL-QR	N/A	15'x10'
	48	UPRIGHT	BRASS	200	4.20	1/2"	V4215	VICTAULIC	FL-QR	N/A	130 SF
	2	SIDEWALL	WHITE	200	4.20	1/2"	V4226	VICTAULIC	FL-QR	SEMI-RECESS	14'x14'
	1189 TOTAL SPRINKLERS										

SPRINKLER HEAD LEGEND

GENERAL NOTES

1. SYSTEM INSTALLED PER NFPA-13 (2016 EDITION) AND STATE FIRE MARSHAL
2. ALL EQUIPEMENT FOR THIS SYSTEM SHALL BE U.L. LISTED
3. MINIMUM PIPE SIZE SHALL BE 1" NOMINAL PIPE
4. ALL SCH-10 & LIGHTWALL PIPING HAS WELDED OUTLETS & GROOVED SHORT RADIUS FITTINGS ALL WELDING PER NFPA-13(3-6.2)
5. NO INSTALLATION OR FABRICATION TO BEGIN WITHOUT APPROVED SHOP DRAWINGS
6. ALL PIPE LOCATIONS ARE TO BE FIELD MEASURED PRIOR TO FABRICATION AND INSTALLTION BY SPRINKLER CONTRACTOR
7. ALL DIMENSIONS SHOWN ARE CENTER TO CENTER
8. HIGH TEMPERATURE HEADS ARE TO BE FIELD LOCATED WHERE REQUIRED
9. PROVIDE ON SPARE HEAD CABINET w/6 HEADS & 1 HEAD WRENCH
10. HANGERS ARE TO BE U.L. LISTED AND F.M. APPROVED
11. ELECTRICAL WIRING, ALARM, DETECTION AND SUPERVISORY BY OWNER
12. OWNER'S RESPONSIBILITY TO PROVIDE ADEQUATE HEATING TO PREVENT WET SYSTEM PIPING FROM FREEZING.

NO	REVISIONS	DATE
1	AHJ REVISIONS	10/15/2025

APPROVAL STAMPS

Drawing Title: FIRE PROTECTION PLAN

THE VIEWS ON 7TH

7TH AVENUE SE
LITTLE FALLS, MN 56345

Contract No. C25-9
Drawing Date: 6/9/25
Scale: 1/8" = 1'-0"
Drawn By: DVG
Approval By: STATE FIRE MARSHAL DIV.
SHEET NO. FP 5 of 6



Design Area #: **13** HAZARD: **LIGHT**
Zone: **4** System Type: **DRY**
Location: **ATTIC**

Flowing Outlets: **29**
Density: **0.10** Remote Area: **2536**
Flow: **592** gpm @ **53.8** psi
Calculation Safety: **6.4** psi
Includes **100** gpm Hose allowance

NOTE:
REMOTE AREA INCREASED 30% FOR DRY
SYSTEM AND 30% FOR SLOPE OF 4:12.
MINIMUM TOTAL REMOTE AREA IS 2535 S.F.

ROOF-A FIRE SPRINKLER PLAN
SCALE= 1/8" : 1'-0"



KEY PLAN



ROOF-B FIRE SPRINKLER PLAN
SCALE= 1/8" : 1'-0"

CALC PLACARD

Design Area #: **9** HAZARD: **LIGHT**
Zone: **4** System Type: **DRY**
Location: **ATTIC**

Flowing Outlets: **29**
Density: **0.10** Remote Area: **2580**
Flow: **620** gpm @ **54.6** psi
Calculation Safety: **5.3** psi
Includes **100** gpm Hose allowance

NOTE:
REMOTE AREA INCREASED 30% FOR DRY
SYSTEM AND 30% FOR SLOPE OF 4:12.
MINIMUM TOTAL REMOTE AREA IS 2535 S.F.



KEY PLAN

PIPE LEGEND

- BLACK STEEL FIRE SPRINKLER PIPING
- CPVC FIRE SPRINKLER PIPING
- FIRE SPRINKLER STANDPIPE PIPING

SYM	CNT	POSITION	FINISH	TEMP	K	NPT	SIN	MFG.	MODEL#	ESCUTCHEON	MAX SPACING
	1	SIDEWALL	BRASS	200	11.20	3/4"	TY5332	TYCO	ELOSW20	SEMI-RECESS	16'x20'
	90	UPRIGHT	BRASS	200	5.60	1/2"	V2703	VICTAULIC	FL-SR	N/A	130 SF
	37	UPRIGHT	BRASS	200	14.00	3/4"	V3425	VICTAULIC	FL-ECOH	N/A	20'x20'
	94	PENDENT	WHITE	200	5.60	1/2"	V2708	VICTAULIC	FL-QR	SEMI-RECESS	15'x15'; 130 SF OH
	268	UPRIGHT	BRASS	200	5.60	1/2"	V2704	VICTAULIC	FL-QR	N/A	15'x15'; 130 SF OH
	376	PENDENT	WHITE	155	4.90	1/2"	V4906	VICTAULIC	FL-RES	SEMI-RECESS	18'x18' UNO
	69	SIDEWALL	WHITE	200	5.60	1/2"	V2710	VICTAULIC	FL-QR	SEMI-RECESS	14'x14'; 130 SF OH
	171	SIDEWALL	WHITE	155	4.40	1/2"	V4431	VICTAULIC	FL-RES/SW	SEMI-RECESS	16'x16'
	11	SIDEWALL	WHITE	155	4.00	1/2"	V6486	VIKING	FREEDOM	SEMI-RECESS	16'x16'
	13	PENDENT	WHITE	200	2.80	1/2"	V4215	VICTAULIC	FL-QR	SEMI-RECESS	15'x15'
	9	SPRIG	BRASS	200	5.60	1/2"	V2704	VICTAULIC	FL-QR	N/A	15'x15'
	48	UPRIGHT	BRASS	200	4.20	1/2"	V4215	VICTAULIC	FL-QR	N/A	130 SF
	2	SIDEWALL	WHITE	200	4.20	1/2"	V4226	VICTAULIC	FL-QR	SEMI-RECESS	14'x14'
	1189 TOTAL SPRINKLERS										

SPRINKLER HEAD LEGEND

GENERAL NOTES

1. SYSTEM INSTALLED PER NFPA-13 (2016 EDITION) AND STATE FIRE MARSHAL
2. ALL EQUIPEMENT FOR THIS SYSTEM SHALL BE U.L. LISTED
3. MINIMUM PIPE SIZE SHALL BE 1" NOMINAL PIPE
4. ALL SCH-10 & LIGHTWALL PIPING HAS WELDED OUTLETS & GROOVED SHORT RADIUS FITTINGS ALL WELDING PER NFPA-13(3-6.2)
5. NO INSTALLATION OR FABRICATION TO BEGIN WITHOUT APPROVED SHOP DRAWINGS
6. ALL PIPE LOCATIONS ARE TO BE FIELD MEASURED PRIOR TO FABRICATION AND INSTALLTION BY SPRINKLER CONTRACTOR
7. ALL DIMENSIONS SHOWN ARE CENTER TO CENTER
8. HIGH TEMPERATURE HEADS ARE TO BE FIELD LOCATED WHERE REQUIRED
9. PROVIDE ON SPARE HEAD CABINET w/6 HEADS & 1 HEAD WRENCH
10. HANGERS ARE TO BE U.L. LISTED AND F.M. APPROVED
11. ELECTRICAL WIRING, ALARM, DETECTION AND SUPERVISORY BY OWNER
12. OWNER'S RESPONSIBILITY TO PROVIDE ADEQUATE HEATING TO PREVENT WET SYSTEM PIPING FROM FREEZING.

NO	REVISIONS	DATE
1	AHJ REVISIONS	10/15/2025

APPROVAL STAMPS

Drawing Title: FIRE PROTECTION PLAN

THE VIEWS ON 7TH
7TH AVENUE SE
LITTLE FALLS, MN 56345

Contract No. C25-9
Drawing Date: 6/9/25
Scale: 1/8" = 1'-0"
Drawn By: DVG
Approval By: STATE FIRE MARSHAL DIV.
SHEET NO. FP 6 of 6